



GENERAL NOTES:

1. NO NATURAL OR MAN-MADE BARRIERS SUCH AS WALLS, FENCES, POSTS, CURBS, SHRUBBERY, OR TREES SHALL BE INSTALLED SO AS TO IMPEDE THE USE, ACCESS, OR OPERATION OF HYDRANTS. MINIMUM CLEAR DISTANCE TO HYDRANT SHALL BE THREE (3) FEET.
2. IN AREAS WHERE HYDRANT INSTALLATION IS TO BE IN ROADWAY, PARKING LOT OR OTHER AREAS WHERE VEHICULAR TRAFFIC MAY CAUSE DAMAGE TO THE HYDRANT, PROTECTIVE BARRIERS ARE TO BE INSTALLED, AS DIRECTED BY THE ENGINEER.
3. HYDRANTS ALONG STREETS SHALL BE LOCATED IN THE TREE LAWN AREA OF THE RIGHT-OF-WAY, NOT LESS THAN 2' FROM THE BACK OF CURB AND NOT MORE THAN 5'.



ENGINEERING DIVISION
44 W. HEBBLE AVENUE FAIRBORN, OHIO 45324
PH: (937) 754-3055 FX: (937) 879-7395

FIRE HYDRANT ASSEMBLY

DWG NO: **WT-2.0**

NOTE 1: DRAWING VALID ONLY WHEN USED AS SHOWN AND IN CONJUNCTION WITH OTHER FAIRBORN ENGINEERING SPECIFICATIONS AND/OR DETAILS. THIS DRAWING REPRESENTS MINIMUM STANDARDS. ANY MODIFICATIONS TO THIS DETAIL SHALL FIRST BE SUBMITTED TO THE CITY ENGINEER FOR APPROVAL.

NOTE 2: CALL THE FOLLOWING AGENCIES IN AT LEAST 48 HOURS IN ADVANCE OF ANY EXCAVATION:
O.U.P.S. AT 8-1-1 AND O.A.G.P.U.P.S. AT (800) 925-0988

ISSUE DATE: **03/14/2017**

ENGR: **MAJ**

APPROVED: **DPO**

SCALE: **NONE**

FILE:

REV NO.	REV DATE	REV DESCRIPTION	REV NO.	REV DATE	REV DESCRIPTION