



NOTES:

1. LINE FOR FIRE SUPPLY SHALL BE HYDROSTATICALLY TESTED AT 200 PSI FOR 2 HOURS AND SHALL BE WITNESSED BY THE FIRE MARSHAL, OR DESIGNATED REPRESENTATIVE.
2. WATER MAIN SHALL BE COVERED PRIOR TO TEST.
3. ENGINEERING AND FIRE DEPARTMENT SHALL BE NOTIFIED 24 HOURS PRIOR TO TEST.
4. WATER VALVE AND CURB STOP SHALL BE LOCATED BETWEEN THE CURB AND SIDEWALK, UNLESS OTHERWISE APPROVED BY THE ENGINEER.
5. WATER VALVE TO BE LOCATED BETWEEN CURB AND SIDEWALK ON THE SIDE CLOSEST TO WATER MAIN.



ENGINEERING DIVISION
 44 W. HEBBLE AVENUE FAIRBORN, OHIO 45324
 PH: (937) 754-3055 FX: (937) 879-7395

FIRE LINE CONNECTION DETAIL

DWG NO: **WT-2.1**

NOTE 1: DRAWING VALID ONLY WHEN USED AS SHOWN AND IN CONJUNCTION WITH OTHER FAIRBORN ENGINEERING SPECIFICATIONS AND/OR DETAILS. THIS DRAWING REPRESENTS MINIMUM STANDARDS. ANY MODIFICATIONS TO THIS DETAIL SHALL FIRST BE SUBMITTED TO THE CITY ENGINEER FOR APPROVAL.

NOTE 2: CALL THE FOLLOWING AGENCIES AT LEAST 48 HOURS IN ADVANCE OF ANY EXCAVATION:
O.U.P.S. AT 8-1-1 AND O.A.G.P.U.P.S. AT (800) 925-0988

ISSUE DATE: **03/14/2017**

ENGR: **MAJ**

APPROVED: **DPO**

SCALE: **NONE**

FILE:

| REV NO | REV DATE | REV DESCRIPTION | REV NO | REV DATE | REV DESCRIPTION |
|--------|----------|-----------------|--------|----------|-----------------|
| | | | | | |
| | | | | | |