



**NOTES:**

1. ALL JOINTS TO BE RESTRAINED.
2. THRUST BLOCKING IS NOT ACCEPTABLE.
3. ALL FASTENERS SHALL BE STAINLESS STEEL.



**ENGINEERING DIVISION**  
 44 W. HEBBLE AVENUE FAIRBORN, OHIO 45324  
 PH: (937) 754-3055 FX: (937) 879-7395

**WATER MAIN OFFSET RELOCATION**

**NOTE 1:** DRAWING VALID ONLY WHEN USED AS SHOWN AND IN CONJUNCTION WITH OTHER FAIRBORN ENGINEERING SPECIFICATIONS AND/OR DETAILS. THIS DRAWING REPRESENTS MINIMUM STANDARDS. ANY MODIFICATIONS TO THIS DETAIL SHALL FIRST BE SUBMITTED TO THE CITY ENGINEER FOR APPROVAL.

**NOTE 2:** CALL THE FOLLOWING AGENCIES AT LEAST 48 HOURS IN ADVANCE OF ANY EXCAVATION:  
 O.U.P.S. AT 8-1-1 AND O.A.G.P.U.P.S. AT (800) 925-0988

REV NO.	REV DATE	REV DESCRIPTION	REV NO.	REV DATE	REV DESCRIPTION

DWG NO: **WT-6.0**

ISSUE DATE: **03/14/2017**

ENGR: **MAJ**

APPROVED: **DPO**

SCALE: **NONE**

FILE: