



ITEM	REQUIRED	SIZE	DESCRIPTION
1	1	8"	FM APPROVED COMPOUND METER ASSEMBLY (BY CONTRACTOR)
2	2	8"	HAND WHEEL GATE VALVES, FLANGED
3	1	6"	O.S.Y. VALVE, FLANGED
4	1	2"	HAND WHEEL GATE VALVE, SCREWED
5	1	2"	BRASS PLUG
6	2	8" X 6"	CAST IRON TEES, FLANGED
7	2	6"	CAST IRON ELBOWS, FLANGED LR
8	6	6" X 11"	CAST IRON FLANGE, 8 HOLE
9	85"	6"	GALVANIZED PIPE, EXTRA HEAVY
10	1	2" X 4-1/2"	BRASS NIPPLE
11	7	8"	FLANGED GASKETS
12	7	6"	FLANGED GASKETS
13	112	3/4" X 3-1/2"	MACHINE BOLTS
14	8	3/4" X 4-1/4"	STUD BOLTS
15	120	3/4"	HEX NUTS
16	2	8" X 13-1/2"	CAST IRON FLANGE, 8 HOLE
17	8"	8"	GALVANIZED PIPE, EXTRA HEAVY

METER PIT MATERIALS

DWG NO: **WT-3.2**

NOTE 1: DRAWING VALID ONLY WHEN USED AS SHOWN AND IN CONJUNCTION WITH OTHER FAIRBORN ENGINEERING SPECIFICATIONS AND/OR DETAILS. THIS DRAWING REPRESENTS MINIMUM STANDARDS. ANY MODIFICATIONS TO THIS DETAIL SHALL FIRST BE SUBMITTED TO THE CITY ENGINEER FOR APPROVAL.

NOTE 2: CALL THE FOLLOWING AGENCIES AT LEAST 48 HOURS IN ADVANCE OF ANY EXCAVATION:
O.U.P.S. AT 8-1-1 AND O.A.G.P.U.P.S. AT (800) 925-0988

ISSUE DATE: **01/25/2019**

ENG'R: **MAJ**

APPROVED: **TLH**

SCALE: **NONE**

FILE:

REV NO.	REV DATE	REV DESCRIPTION	REV NO.	REV DATE	REV DESCRIPTION



ENGINEERING DIVISION
44 W. HEBBLE AVENUE FAIRBORN, OHIO 45324
PH: (937) 754-3055 FX: (937) 879-7395