



City of Fairborn
44 W. Hebble Avenue
Fairborn, OH 45324
p: 937.754.3075
f: 937.879.7024

Frank Barosky
Wastewater Manager

Water Reclamation Center Clarifier Painting Project Bid No. 19-11, Addendum 1

1. For the immersion and non-immersion coatings there will be a cut off to apply the coating on the mixer. The immersion coating system should extend to 6" above the water line. Non-immersion system should be applied to the remainder of the equipment above that point.

2. Regarding containment around the structure being blasted, all federal, state, and local statutes and restrictions must be followed. Abrasive blasting method selection is at the discretion of the contractor and subject to the approval of the City. In the event that the surface preparation method requires containment in order to comply with applicable statutes and restrictions, SSPC Class I or Class II containment is recommended and such cost is to be included in the Base Bid Amount. It should also be noted that local weather conditions at time of application may necessitate containment in order to facilitate heating and dehumidification measures required to achieve acceptable application conditions. Containment required to maintain application conditions is the responsibility of the contractor and such cost is to be included in the Base Bid Amount.

Frank Barosky